

**DEKALB LAGOON IMPROVEMENTS  
TOWN OF DEKALB  
KEMPER COUNTY, MISSISSIPPI**

**ADDENDUM NO. 2**

TO: ALL BIDDERS ON THE ABOVE REFERENCED PROJECT  
FROM: Richmond L. Alexander, P.E.  
DATE: November 15, 2016  
SUBJECT: **ADDENDUM NO. 2**

Clarifications and Modifications to contract documents issued for the referenced project include the following:

1. Sand for filter lagoons meeting requirements of the Mississippi Department of Transportation Type "B" filter material shall be acceptable. Gradation requirements for Type "B" filter material is as follows:

<u>Sieve Size:</u>	<u>Percent Passing by Weight:</u>
1/2"	100
3/8"	97-100
No. 4	92-100
No. 8	75-100
No. 16	45-90
No. 30	25-70
No. 50	3-35
No. 100	0-10

\*Material with a maximum 2% passing the No. 200 sieve is acceptable.

  
Submitted By: \_\_\_\_\_  
Project Engineer

11/15/16  
Date

Acknowledged By: \_\_\_\_\_  
Contractor

\_\_\_\_\_  
Date:

**THIS ADDENDUM SHALL BE SIGNED, DATED AND SUBMITTED WITH BID DOCUMENTS. FAILURE TO ACKNOWLEDGE RECEIPT OF THIS ADDENDUM AND ATTACH IT TO CONTRACT DOCUMENTS SHALL BE GROUNDS FOR REJECTING PROPOSAL.**