

**FACILITY ADDITION FOR  
EMILIA RESOURCES  
ARC GRANT NO. MS-19249-2018  
KEMPER COUNTY BOARD OF SUPERVISORS  
KEMPER COUNTY, MISSISSIPPI**

**ADDENDUM NO. 4**

TO: ALL BIDDERS ON THE ABOVE REFERENCED PROJECT

FROM: Terrell W. Temple, P.E.

DATE: January 7, 2019

SUBJECT: ADDENDUM NO. 4

1. **DELETE** the '8" lime treatment subgrade' shown on Concrete Pavement Details sheet C5.0. All other requirements indicated on the detail shall remain.
2. **CLARIFICATION:** Gas lines smaller than 2 ½" may be threaded in lieu of welded.
3. **CLARIFICATION:** Quality control testing for earthwork and for concrete is to be provided at no cost to the Contractor.

Submitted By:



\_\_\_\_\_  
Project Engineer

\_\_\_\_\_  
Contractor

January 7, 2019  
\_\_\_\_\_  
Date

\_\_\_\_\_  
Date

**THIS ADDENDUM SHALL BE SIGNED, DATED AND SUBMITTED WITH BID DOCUMENTS.**

**FAILURE TO ACKNOWLEDGE RECEIPT OF THIS ADDENDUM AND ATTACH IT TO CONTRACT DOCUMENTS SHALL BE GROUNDS FOR REJECTING PROPOSAL.**